



# Commercial Building Electrical Inspection Checklist

- Identify installations that are covered by the NEC
- Confirm that all installations follow their required instructions and that materials are properly labeled
- Verify that interrupting current and SC current ratings are acceptable for the installation's conditions
- Confirm that all unused openings are properly closed
- Check for contamination caused by the use of foreign materials
- Check for damaged or unrepaired parts
- Check for solidified mounting and ventilation
- Look for temperature, proper use, and electrical ratings of terminations and splices
- Verify ratings of the surrounding environment and check for enclosure markings
- Verify adequate headroom around the equipment and satisfactory working clearances
- Check for circuit directories for switchboards, panel boards, and similar equipment
- 
- 

